

Smoke Generator Performance Assessment

IASFPF 08-09 May 2018

Dr. André Freiling, Expert


AIRBUS

Background

How shall a reference smoke generation source for future smoke detector integration verification look like?




2005 Assessment




This assessment has been used by Airbus since 2005

2005 Assessment

The shown values are the result of only one measurement for each program sequence:
No statistical evidence.



2017 Are-assessment





The 2005 setup was reproduced and documented in more detail



Test Mock-Up with MIREX and AML



Recent studies: Re-assessment of “reference curve”



- Smoke Generator Light Obscuration shows good average match
- Statistical deviations
- Justification for averaging during flight testing

Siemens Smoke Generator



Recent studies: Re-assessment of “reference curve”



- Settings for the Aviator Smoke Generator could be achieved to match with the 2005 reference curve

Aviator Smoke Generator

Smoke Density Measurements in EN54 room environment





- In a different environment (EN 54 room), the results of smoke density measurements differ between the 2 generators.
- Smoke dynamics and spreading becomes visible in the enlarged room with higher dilution

Particle Size distribution measurement

- The data were recorded with the Palas-Welas system
- It counts the number of particles of 192 size-classes in the range of particles with diameters $d = 0.2 - 10 \mu\text{m}$.
- A dilution system with a dilution factor of 1:10 was implemented just before the Palas-Welas system due to high expected smoke concentration



Particle size distribution of smoke generators under test



Particle size distribution of Siemens and Aviator Smoke Generator are matching

Conclusion

Summary

- Siemens and Aviator smoke generators show good match in unventilated wooden aircraft cargo compartment mock-up
- Different results for Siemens and Aviator Smoke Generator occur in a different environment (EN54 room)
- Particle size distribution matches well between Siemens and Aviator Smoke Generator

Next steps

- Discussion on feasibility of a standardized smoke generator calibration approach
- International agreement on reference
- Investigations on in-flight changes of smoke generator application (cabin pressure, cargo door leakage, etc.)
- Correlation to Smoke Detector responses

Acknowledgements

- Rainer Hadamek, Airbus Fire Protection Design Office
- Dr. Thorsten Schultze and Wolfgang Krüll, University of Duisburg-Essen

Thank you