

Full-scale Demonstration Testing with a Solid Aerosol Fire Extinguishing Agent, Discussion Transitioning...



Federal Aviation
Administration

Presented to: International Aircraft Systems Fire
Protection Working Group

By: on behalf of :

Doug Ingerson

Federal Aviation Administration

WJ Hughes Technical Center

Fire Safety Team

Atlantic City Int'l Airport, NJ USA

tel : 609-485-4945

email : douglas.a.ingerson@faa.gov

Date: 15Nov2012



Presentation Overview

~ Major Discussion Points

Testing with a Solid Aerosol

- Purpose
- Test Conditions/Circumstances
- Various Views of the Nacelle Test Article
- Some Observations
- Outcomes
- Conclusions

Current Status, Engine Nacelle Halon Replacement Activity, FAATC

References within this presentation to businesses, their services and/or products does not constitute endorsement.



Full-scale Demonstration Testing, Solid Aerosol

~ Purpose

Purpose

- Boeing/Kidde interested in solid aerosol fire extinguishing (firex) agent for aircraft engine nacelle application
- Firex agent subjected to MPSHRe rev04⁽¹⁾ testing
 - product is manufactured by Kidde & known as KSA
 - generic/“Part A” testing, 2010-2011
 - accomplished in FAATC generic nacelle fire simulator
 - industry established design criteria for “Part B” testing
 - high-fidelity/“Part B” demonstration testing, 2011-2012
 - invoked by the FAA due to notable dissimilarities between this candidate & the typical firex solution of halon 1301
 - parties agreed to use Pratt & Whitney JT9D on an FAA-owned Boeing 747SP

(1) MPSHRe revision 04, http://www.fire.tc.faa.gov/pdf/systems/MPSErev04_MPSeRev04doc-02submtd.pdf

Full-scale Demonstration Testing, Solid Aerosol

~ Test Conditions/Circumstances

Test Conditions/Circumstances

- JT9D nacelle forcibly ventilated externally from atmosphere
 - air mass flow rate ≈ 0.5 kg/s (1 lbm/s)
 - ran engine to “heat” nacelle environment before pertinent tests
- Nacelle fire threat
 - *simultaneously* burning JP-8 spray & pool fires
 - JP-8 spray delivered @ ~ 180 mL/min @ 46°C (0.05 gpm @ 115°F)
 - JP-8 pool of $19.1 \times 26.8 \times \sim 1.3$ cm deep ($7.5 \times 10.5 \times \sim 0.5$ in)
 - fires electrically ignited; igniters de-energized after ignition
 - looked for fire *extinguishment*, not reignition behavior
- Industry provided firex system & concentration analyzer
 - sodium bicarbonate-based solid aerosol
 - optical system used to measure agent distribution

Full-scale Demonstration Testing, Solid Aerosol

~ Test Conditions/Circumstances

Test Conditions/Circumstances


- Additional comments
 - intent of nacelle fire protection changed during “build-up”
 - initial intent to represent design criteria throughout fire zone
 - final design simultaneously represented design criteria solely at both fire regions; 4 concentration sample points per region
 - ran 2 fire extinguishment tests 11 Jul 2012
 - 1ST test ran with N₂ injection
 - verify fire threats/challenge of sufficient intensity
 - expected NO fire extinction
 - 2ND test ran with solid aerosol injection
 - represent design criteria & demonstrate fire extinguishment
 - expected fire extinguishment

Full-scale Demonstration Testing, Solid Aerosol

~ Test Conditions/Circumstances


Test Conditions/Circumstances

- General/intended test time line



Imagery of these various details can be found in this presentation & in the appendix of this file. The appendix imagery has been previously presented & is not part of this presentation.

Various Views, Schematic Site Plan



Full-scale Demonstration Testing, Solid Aerosol

~ Some Observations, General Comments

Some Observations, General Comments

- Data is provided here for “high” level review; data :
 - is from the 2ND test of 11jul (test 201271106)
 - represents the test challenging the solid aerosol’s design criteria
- Data is visual & numerical
 - related to the :
 - general nacelle area, thermal
 - spray fire region, visual & thermal
 - pool fire region, visual & thermal
 - the following slides are provided in an organized manner
 - grouped by region; general nacelle, fire region
 - leads with pertinent imagery for familiarization
 - follows with numerical data in graph format, as applicable

Full-scale Demonstration Testing, Solid Aerosol

~ Some Observations/Visual Behaviors

Some Observations, Visual Behaviors

- Fire behaviors were recorded by cameras viewing the pool & spray fire regions
- Camera details
 - housed in windowed/metal boxes ventilated from/to nacelle exterior
 - principally recording visible spectrum
 - captured at frame rate ≈ 15 frames per second
- Other comments
 - images are shown which were taken from the digital video records
 - 8 images shown for each fire region, incrementing at ≈ 1.6 sec
 - images span the firex agent pulse, pre-discharge to post-migration
 - as solid aerosol injects, it creates a cloud that obscures visibility
 - looked for light to indicate whether fire remained or not

Full-scale Demonstration Testing, Solid Aerosol

~ Some Observations/Temperatures


Some Observations, Thermal Conditions

- Some temperature behaviors are included here
- Thermocouple descriptions
 - all type-K
 - all here are sampling the nacelle gas stream
 - the data here represents positions principally in the nacelle
 - several scattered about the nacelle (3 graphs)
 - 1 point sampling the inlet air entering the engine
 - 12 points in the nacelle
 - 8 points local to the spray fire (1 graph)
 - 8 points local to the pool fire (1 graph)

viewing outboard side of engine

(photo taken BEFORE pool & spray fire hardware was installed)

Various Views, Thermocouple Locations from Outboard View





Various Views, Thermocouple Locations from Inboard View

viewing inboard side of engine


(photo taken BEFORE pool & spray fire hardware was installed)

S0x, spray fire thermocouples

P0x, pool fire thermocouples
(supported by hardware cloth)




Thermocouple Behaviors, "Original" 12 Locations, 1-4



pres20121115.xls, orig TCs01-04




Thermocouple Behaviors, "Original" 12 Locations, 5-8



pres20121115.xls, orig TCs 05-08





Thermocouple Behaviors, "Original" 12 Locations, 9-12



pres20121115.xls, orig TCs09-012



Various Views, Nacelle Spray Fire Threat, Concentration Sample Points & Video Camera Location



VIDEO CAMERA, SPRAY FIRE

FUEL SPRAY NOZZLE

CONCENTRATION SAMPLE POINT (typical)

Spray Above Camera

Spray Nozzle

FUEL SPRAY NOZZLE

Spray Between 16/17

Spray Inline (between thermal shield and engine case)

Full-scale Demonstration Testing, Solid Aerosol

~ Some Observations/Spray Fire Visual Record



with OBVIOUS FIRE



with minimal FIRE



Full-scale Demonstration Testing, Solid Aerosol

~ Some Observations/Spray Fire Visual Record




Full-scale Demonstration Testing, Solid Aerosol


~ Some Observations/Spray Fire Visual Record



viewing outboard side of engine in spray fire region

Various Views, Thermocouple Locations, Spray Fire Threat





Full-scale Demonstration Testing, Solid Aerosol

~ Some Observations/Summary – Spray Fire Region

Some Observations, Summary/Spray Fire Region

- 1ST test/11Jul (test 201271103)
 - N₂ injection did not extinguish the spray fire
 - parts of 2 door seals continued burning after fuel flow stopped
 - seals are located on cowl door's inner face near the spray fire
 - similar to fiberglass/"high-temperature" silicone gasket material
- 2ND test/11Jul (test 201271106)
 - region remained illuminated throughout the firex agent exposure
 - after the firex agent pulse passed, the spray fire was burning
 - seals continued burning after fuel flow stopped
 - thermal traces
 - indicates flames are pushed around during injection
 - average trend remained steady to increasing

Various Views, Nacelle Pool Fire Threat, Concentration Sample Points & Video Camera Location

CONCENTRATION
SAMPLE POINT (typical)

viewing aft/underside of the #2 engine

BUNDLE "A"

COPPER TEE

VIDEO CAMERA,
POOL FIRE

FWD

OUTBOARD
(LEFT)


Aft 06:00

Pan Inboard

Pan Mid
(between fuel pan & core)

Pan Outboard
(between fuel pan & core)

FUEL PAN



Full-scale Demonstration Testing, Solid Aerosol

~ Some Observations/Pool Fire Visual Record



ELAPSING TIMER, HH:MM:SS.SS




Full-scale Demonstration Testing, Solid Aerosol

~ Some Observations/Pool Fire Visual Record



Various Views, Thermocouple Locations, Pool Fire Threat



viewing top of fuel pan from outboard

P02

P01


P06

P05

UP

FWD

FUEL PAN



P04

P03

P07

FWD

OUTBOARD (left)

P08

P01


P02

FUEL PAN

P05

P06

Thermocouples P01, P02, P03, P05, P06, & P08 are obscured in this image by structures.



pres20121115.xls, pudl TC's



Full-scale Demonstration Testing, Solid Aerosol

~ Some Observations/Summary – Pool Fire Region

Some Observations, Summary/Pool Fire Region

- N₂ did not extinguish the pool fire in 1ST test/11Jul
- 2ND test/11Jul
 - region remained mostly illuminated during the firex agent pulse
 - analog video record captured interesting behavior (not shown here)
 - occurred 00:09:46 – 00:09:48 (elapsing timer)
 - flames are pushed inboard, rotated around engine core beyond inboard limit of view field, view field briefly ($t < 0.23$ sec) went dark, then light intensity obviously increased near 06:00/BDC
 - after the firex agent pulse passed, the pool fire was burning
 - thermal traces
 - indicated flames are pushed around during injection
 - average trend decreased briefly but regained steady-state

Full-scale Demonstration Testing, Solid Aerosol

~ Outcomes

Outcomes

- The challenge to the design criteria was reasonable.
 - occurred in a “real” engine nacelle environment
 - spray & pool fire threats were present
 - all added to create the spray & pool fire threats were similar in character to that already in the nacelle
- The firex system “protected” part of the nacelle fire zone.
- The firex agent distribution surrounded each fire region simultaneously while representing the design criteria.
- The spray & pool fires did not extinguish in either test.
- 2 cowl door seals near the spray fire continued burning after fuel flow stoppage.

Full-scale Demonstration Testing, Solid Aerosol

~ Outcomes/Next Steps

Outcomes/Next Steps

- Following 11 Jul test outcome, industry/FAA discussion continued; opinions differed about the next steps.
- Given the test outcome, FAA & industry goals diverged.
 - industry reasonably wants to understand the test outcome
 - FAA support falters because progression to a recommendation for certification, the basis for support, is not possible in the near-term
- FAATC offered additional/constrained support.
 - focus to understand the test environment, not the candidate
 - any focus on the candidate taken as development work, the obligation of the industry team

Full-scale Demonstration Testing, Solid Aerosol

~ Outcomes/Next Steps

Outcomes/Next Steps

- FAATC offer of further 747SP support
 - work to better understand fire behaviors/intensities
 - assess the situation with something “familiar”; use halon 1301
 - represent 6%v/v for 0.5 sec across the same 8 sample points
 - firex system creation at industry expense
 - FAATC-imposed deadline
 - assess intensity via extinguishment; i.e. if not extinguished, threats too severe, else threats reasonably severe; react accordingly
- Given the difference here between FAA & industry constraints, industry declined the offer of this support.

Full-scale Demonstration Testing, Solid Aerosol

~ Conclusions

- Given no fire extinguishment subject to N₂ injection, the fire threats were considered sufficiently intense.
- Given no fire extinguishment when subject to the solid aerosol injection, the represented design criteria did not demonstrate fire extinguishment.
- The firex agent & its distribution measurement observably differ from history. Change in firex design rationale, acknowledging these differences, may alter outcome.
- Currently, the FAATC provides no further significant support regarding this solid aerosol. Industry action continues.
 - resuming FAA support remains possible, contingent upon the development of plausible knowledge
 - the form of any future support is not known at this time

Current Status

~ Engine Nacelle Halon Replacement Activity, FAATC

- No significant testing planned.
- Significant report creation planned.
 - MPSHRe report, to include :
 - test process development
 - work with :
 - HFC-125
 - CF₃I
 - 2-BTP
 - FK-5-1-12
 - KSA
 - MPSHRe rev03; given HFC-125 & CF₃I outcomes per rev03
 - MPSHRe rev04
 - “cold” FK-5-1-12 technical note

End of Presentation

- **Acronyms, definitions, short-hand notations**

approx = approximately

BDC = bottom dead center

FAA = United States Federal Aviation Administration

FAATC = FAA W.J. Hughes Technical Center

firex = fire extinguishing or fire extinguishing system

FWD = forward

MPSHRe = Minimum Performance Standard for Halon Replacement in Civil Aircraft Engine Nacelle & APU Compartments

rev = revision



Appendix Imagery




Various Views, Nacelle Ventilation, Supply

FUEL SYSTEM CART

JT9D

SUPPLY BLOWER







Various Views, Nacelle Spray Fire Threat, General Site Orientation

CAMERA, SPRAY FIRE

FUEL SPRAY NOZZLE &
ELECTRICAL IGNITION ARC GAP





- Fuel pan is made from 14 ga steel & approximately 191 x 267 x 64 x mm tall (7.5 x 10.5 x 2.5 in tall)
- Fuel puddle depth approximately 13 mm (0.5 in) & freeboard (dry lip) height approximately 25 mm (1 in)
- Base of fuel pan is hollow permitting water flow from a water jacket

Various Views, Nacelle Pool Fire Threat, General Site Orientation

