

Aircraft Cargo MPS Test of FK-5-1-12

The Evaluation of FK-5-1-12 as a Halon
1301 Replacement for Aircraft Cargo
Compartment Fire Protection Application

Presented to: International Aircraft Systems Fire
Protection Working Group Meeting

By: John Reinhardt, Aerospace Engineer

Date: October 25-26, 2006



Federal Aviation
Administration



Outline



- **Agent & System Information**

- **MPS Tests & Results**

Status

Aerosol Can Simulation Explosion Test

Surface Burn Test

Containerized Fire Test

Bulk-Load Fire Test

- **Final Remarks**



Outline

- **Agent & System Information**

- **MPS Tests & Results**

Status


Aerosol Can Simulation Explosion Test

Surface Burn Test

Containerized Fire Test

Bulk-Load Fire Test

- **Final Remarks**



Agent Information



Compound	Atmospheric Lifetime (yrs)	ODP	GWP ₁₀₀
Halon 1301 (CF ₃ Br)	65	12	6,900
HFC-125 (CF ₃ CF ₂ H)	29	0	3,400
2-BTP (CH ₂ CBrCF ₃)	0.008	0	N/A
FK-5-1-12 (CF ₃ CF ₂ C(O)CF(CF ₃) ₂)	0.014	0	1

Agent Information




Property	Value	Unit
Molecular Weight	316.05	
Boiling Point	49.0	°C
Freezing Point	-108	°C
Liquid density @ 25°C	1600	kg/m ³
Vapor density @ 25°C	13.65	kg/m ³
Vapor Specific volume @ 1bar & 25°C	0.0733	kg/m ³
Vapor pressure @ 25°C	0.404	bar
Specific Heat, vapor @ 1bar & 25°C	0.891	kJ/kg°C
Heat of vaporization @ bp	88.1	kJ/kg
Solubility of water in agent @ 21°C	<0.001	wt%
Dielectric strength rel. to N ₂ @25 °C	2.3	

Agent Information



- EPA SNAP Listed
- Agent disperses as a gas
- No residue
- High density
- Water Insoluble
- High dielectric strength
- Liquid at room temperature



Information provided is courtesy of 3M

Agent Information



AGENT	USE CONC.	NOAEL*	SAFETY MARGIN
FK-5-1-12	4.2 - 6%	10%	67 - 138%
Halon 1301	5%	5%	---
HFC-125	11.3%	7.5%	No
2-BTP	6%	0.5%	No
Inert Gases	38 - 40%	43%	7 - 13%

* No Observable Adverse Effect Level

Information provided is courtesy of 3M



Agent Information



Currently, FK-5-1-12 Successfully Protecting:

- Telecommunication Switch Rooms
- Computer and Electronic Control Rooms
- Hazards Aboard Ships
- Military Engine and Crew Bay
- Flight Line Protection



Information and photographs provided is courtesy of 3M

System Information



PRESSURE VESSEL

- 20 lb Fenwal Protection Systems Cylinder (93-100020-001)
- Fenwal Protection Systems Electric Control Head (486500-01)
- ½” NPT black iron pipe
- Single ½” NPT Nozzle (designed for FK-5-1-12)

FAA TC-10 AIRCRAFT

- 70 lb Fenwal Protection Systems Cylinder (93-100020-001)
- Fenwal Protection Systems Electric Control Head (486500-01)
- 1-½” NPT black iron pipe
- Single 1-½” NPT Nozzle (designed for FK-5-1-12)

Outline

- Agent & System Information
- MPS Tests & Results

Status

Aerosol Can Simulation Explosion Test

Surface Burn Test

Containerized Fire Test

Bulk-Load Fire Test

- Final Remarks




MPS Tests & Results



CARGO MPS TESTING OF FK-5-1-12 STATUS

- Conducted 13 Aerosol Can Simulation Explosions in the 11.4 m³ pressure vessel.
- Conducted 3 Surface Burn Tests (TC-10)
- Conducted 2 Containerized Fire Tests (TC-10)
- Conducted 3 Bulk-Load Tests (TC-10)



Outline

- Agent & System Information
- MPS Tests & Results

Status

Aerosol Can Simulation Explosion Test

Surface Burn Test

Containerized Fire Test

Bulk-Load Fire Test

- Final Remarks



MPS Tests & Results



AEROSOL CAN EXPLOSION SIMULATION TEST (11.4 m³ VESSEL)


Fire Load:

Simulator - 0.2 lb. Propane, 0.6 lb. of denatured alcohol, 0.2 lb of water

Ignition Sources = arcing electrodes (3' away from the simulator)

Heat up simulator to increase pressure in content chamber to 240 psig

FK-5-1-12 FSS Activation = after simulator reached 240 psig



MPS Tests & Results



AEROSOL CAN EXPLOSION SIMULATION TEST (11.4 m³ VESSEL)

Aerosol Can Simulator Activation = after
agent concentration stabilizes and simulator
pressure is at 240 psig.

Test Duration = until the simulator is activated



MPS Tests & Results




FIGURE 1. PRESSURE VESSEL SETUP

MPS Tests & Results



Test No.	Concentration Desired (Vol %)	Agent Quantity (lbs)	Result	Comments
050806T1	4.2	14	No Explosion	Agent filled by OEM. Arc electrodes did not spark.
050806T2	8.1	28	No Explosion	Agent filled by OEM. Arc electrodes did not spark.
071906T1	4.2	14.95	No Explosion	Fill to 14.8 -15.0 lbs with 460 psig N2. Air added to electrodes.
071906T2	8.1	29.96	No Explosion	Fill to 30 lbs with 460 psig N2. Air added to electrodes.
071906T3	2	6.92	No Explosion	Fill to 7.0 lbs with 460 psig N2. Air added to electrodes.
071906T4	0	0	20 psig	Baseline - No agent
07/20/06T1	8.1	30.12	No Explosion	Fill to 30.0 lbs with 460 psig N2. Air added to electrodes.
07/20/06T2	4.2	14.98	No Explosion	Fill to 15.0 lbs with 460 psig N2. Air added to electrodes.
07/20/06T3	2	6.94	No Explosion	Fill to 7.0 lbs with 460 psig N2. Air added to electrodes.
072106T1	1	3.44	33 psig	Fill to 3.4 lbs with 460 psig N2. Air added to electrodes. Explosion same as baseline.
072106T2	2	6.94	34 psig	Fill to 7.0 lbs with 460 psig N2. Air added to electrodes. Explosion same as baseline.
072106T3	4.2	14.8	66 psig	Fill to 15.0 lbs with 460 psig N2. Air added to electrodes. Agent enhanced explosion.
081006T1	4.2	14.8	67 psig	Fill to 15.0 lbs with 460 psig N2. Air added to electrodes. Agent enhanced explosion.



MPS Tests & Results



Aerosol Can Simulator
Explosion Test

Test # 072106T1


1% FK-5-1-12



MPS Tests & Results




AEROSOL CAN SIMULATION EXPLOSION TEST RESULTS



MPS Tests & Results



AEROSOL CAN SIMULATION EXPLOSION TESTS



COMPARISON OF OVERPRESSURE HISTORIES OF VARIOUS AGENTS

Outline

- Agent & System Information

- MPS Tests & Results

Status


Aerosol Can Simulation Explosion Test

Surface Burn Test

Containerized Fire Test

Bulk-Load Fire Test

- Final Remarks



MPS Tests & Results



SURFACE BURN FIRE TEST

Fire Load = 0.5 U.S. Gallon of Jet A fuel (with 13 oz of gasoline) inside
A 2 ft x 2 ft x 0.33 ft pan

Add 13 oz of gasoline to make ignition easier; add 2.5 gallons of water to reduce pan warping.

Place pan in most difficult location (1 ft)


Fire Ignition = Arc created by two electrodes

FSS Activation = 1 min. after one of the ceiling T/C reaches 200 °F

Test Duration = 5 minutes after agent discharge



MPS Tests & Results



MPS Tests & Results





SURFACE BURN TEST RESULTS (56.6 m³ COMPARTMENT)



Test No.	Concentration Desired (Vol %)	Agent Quantity (lbs)	Result	Comments
080106T1	0	0	Fire Peak = 953 F, Area = 1631 F*min	Surface Burn Baseline
080306T1	4.2	74.41	Fire Peak = 294 F, Area = 540 F*min	Filled to 74.4 lbs with 360 psig N2. Test temperature was 95 degF, atm. pressure 29.83", 50% relative humidity
080306T2	0	0	Fire Peak = 972 F, Area = 1653 F*min	Surface Burn baseline



MPS Tests & Results



MPS Tests & Results



Outline



- Agent & System Information

- MPS Tests & Results

Status

Aerosol Can Simulation Explosion Test

Surface Burn Test

Containerized Fire Test

Bulk-Load Fire Test

- Final Remarks



MPS Tests & Results



CONTAINERIZED FIRE TEST

Fire Load = 33 card board boxes
inside an LD3. 3 LD3 in Compartment

Two ventilation slots in main LD3
container size 12" x 3" +/-1/4 (access
panel, and lower right panel)

The LD3 access panel is made out of
0.08" polycarbonate sheet

Fire Ignition = 7 ft of nichrome wire wrapped
around four folded paper towels (Energized with
120 Vac)



MPS Tests & Results




CONTAINERIZED FIRE TEST (CONT.)



FSS Activation = 1 min. after one of the ceiling
T/C reaches 200 °F

Test Duration = Four tests @ 30 minutes each;
fifth test shall
for at least 180 minutes. Hybrid systems shall run
for 180 min.

MPS Tests & Results




MPS Tests & Results




MPS Tests & Results



MPS CONTAINERIZED FIRE TEST 081506T1
FK-5-1-12: First Discharge: 8.1%, Second Discharge: 4.2%



MPS CONTAINERIZED FIRE TEST 081506T1
FK-5-1-12: First Discharge: 8.1%, Second Discharge: 4.2%



Outline

- Agent & System Information

- MPS Tests & Results

Status

Aerosol Can Simulation Explosion Test

Surface Burn Test

Containerized Fire Test

Bulk-Load Fire Test

- Final Remarks



MPS Tests & Results



BULK-LOAD FIRE TEST

Fire Load = 178 card board boxes
(30% of Vol.) containing 2.5 lbs
of shredded office paper (strips, not confetti)
at standard room temp.

Boxes nominal dimensions: 18"x18"x18"



Fire Ignition = 7 ft of nichrome wire wrapped around four folded paper towels
(Energized with 120 Vac) inside box (with 1" holes).

Fire Suppression System Activation = 1 minute after one of the ceiling T/C
reaches 200 °F



Test Duration = Four tests @ 30 minutes each; fifth test shall
for at least 180 minutes. Hybrid systems shall run for 180 min.



MPS Tests & Results





MPS Tests & Results



MPS Tests & Results



MPS Tests & Results



Outline

- Agent & System Information
- MPS Tests & Results

Status

Aerosol Can Simulation Explosion Test

Surface Burn Test

Containerized Fire Test

Bulk-Load Fire Test

- Final Remarks



Final Remarks



FK-5-1-12: AIRCRAFT CARGO COMPARTMENT MPS TEST RESULTS

MPS TEST	PASS	FAIL	COMMENTS
Aerosol Can Explosion Simulation Test		X	Modified Test: added air to electrodes to make them arc. Explosion enhancement at below inert concentration. 13 tests conducted.
Surface Burn Test	X		1 out of 5 tests conducted
Containerized Test	X		1 out of 5 tests conducted
Bulk-Load Test		X	Fire re-ignited ~ 3 minutes after the agent was discharged. It reflashed for a second time after the metering agent was consumed. 1 out of 5 tests conducted

For this fire protection application, FK-5-1-12 (as configured and tested) is not effective because it did not meet the FAA acceptance criteria in its entirety.

Final Remarks

Suggestion on solutions to meet Aircraft Cargo Compartment MPS acceptance criteria:

Aerosol Can Simulation Explosion & Bulk-Load Tests:

- Maintain agent at inert concentration at all times
- Or, maintain oxygen level in cargo compartment below 12% using inert gas
- Or, combine agent and inert gas system (three-stage discharge):

FK-5-1-12 HRD → Inert Gas HRD → Inert Gas LRD

(Knockdown Flames → Prevent Re-ignition → Suppress for long period of time)

